

Declaration of Performance

Nr: DoP 13/2019

1. Unique identification code of product-type:

Intumescent seals INTU STRIP / F / FS / FC

2. Intended uses:

Intumescent seals INTU STRIP / F / FS / FC is designed to seal gaps in fire doors with fire resistance class EI 60.

3. Manufacturer:

INTUSEAL Sp. z o.o.
ul. Kineskopowa 1,
05-500 Piaseczno

4. System or systems of Assessment and Verification of Constancy of Performance (AVCP):

System 1

5. European Assessment Document: -

European Technical Assessment: -

Door fire test report – LZP43-02580/16/Z00NZP

Technical Assessment Body: ITB, ul. Filtrowa 1, 00-611 Warszawa

Notified product certification Nr 1488

6. Declared performance:

BWR 1 Mechanical resistance and stability	
-	NA
BWR 2 Safety in case to fire	
Reaction to fire	NA
Resistance to fire	Up to EI 240
BWR 3 Hygiene, health and the environment	
Air permeability	No performance assessed
Water permeability	No performance assessed
Content, emission, release of dangerous substances	No release of dangerous substances
BWR 4 Safety and accessibility in use	
Mechanical resistance and stability	No performance assessed
Resistance to impact/movement	No performance assessed
Adhesion	No performance assessed

BWR 5 Protection against noise	
Aireborne sound insulation	No performance assessed
BWR 6 Energy economy and heat retention	
Thermal properties	No performance assessed
Water vapour permeability	No performance assessed
Use category	
Use category	Z ₂

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Name: Michał Czaiński
Position: Prezes Zarządu

Piaseczno, 02.01.2019
Place, date

INTUSEAL Sp. z o.o.
Prezes Zarządu
Michał Czaiński
.....
Signature