

**DECLARATION OF PERFORMANCE**

No: DoP 3/2025

1. Unique identification code of product-type:

**INTU FR GRILLE DS**

2. Intended uses:

**The intended use of INTU FR GRILLE DS is to reinstate the fire resistance performance of doors.  
Filling ventilation openings in fire resistance doors.**

3. Manufacturer:

**INTUSEAL Sp. z o.o.  
ul. Kineskopowa 1, 05-500 Piaseczno**

4. Authorized representative:

**Not applicable**

5. System or systems of Assessment and Verification of Constancy of Performance (AVCP):

**System 1**

6a. Harmonised standard:

**Not applicable**

Notified body or bodies:

**Not applicable**

6b. European Technical Assessment:

**No. 00518/25/Z00NZP**

Technical Assessment Body:

**ITB, ul. Filtrowa 1, 00-611 Warszawa**

Notified body or bodies:

**No. 1488**

7. Declared performance:

Basic requirements	Performance characteristics
<b>BWR 2 Safety in case to fire</b>	
Reaction to fire	NPD
Resistance to fire	Max. EI 60 – According with Table 2 of European Technical Assessment: No. 00518/25/Z00NZP
<b>BWR 3 Hygiene, health and the environment</b>	
Air permeability	NPD
Water permeability	NPD
Content, emission, release of dangerous substances	NPD
<b>BWR 4 Safety and accessibility in use</b>	
Mechanical resistance and stability	NPD
Resistance to impact/movement	NPD
Adhesion	NPD
Durability	Z <sub>2</sub>
<b>BWR 5 Protection against noise</b>	
Aireborne sound insulation	NPD
<b>BWR 6 Energy economy and heat retention</b>	
Thermal properties	NPD
Water vapour permeability	NPD

8. Appropriate technical documentation or special technical documentation:

**Not applicable**

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.


Signed for and on behalf of the manufacturer by:

Name: Michał Szykowski

Position: President of the Management Board

Piaseczno, 14.01.2025

Place, date

  
Signature